

DeMaria, Eva

From: Johnson, Laura <Laura.Johnson@portlandoregon.gov>
Sent: Thursday, October 23, 2014 10:16 AM
To: Muza, Richard; LIVERMAN Alex
Subject: US Army Corps
Attachments: 2014-10-10 inspection follow up USACE.pdf

Dear Rich and Alex,

I conducted an annual inspection at the US Army Corps facility earlier this month. Attached is a copy of the inspection follow up letter.

In addition to this letter the facility is included in the tier 2 corrective action category for copper and zinc at their stormwater outfall B. Their outfall A did not trigger the tier 2 corrective action requirements, but both outfalls have high iron. The tentative plans I discussed with the site staff to reduce metals are very minimal at the moment, I am not sure the proposal will provide effective reduction levels at the outfall. They want to install clean-way filters with metal zorb enhanced media in two additional basins B1 and B9., to reduce the overall metals at the outfall.

Laura Johnson
503-823-7192